



NEW HANOVER COUNTY FIRE SERVICES

230 Government Center Dr. Suite 130
Wilmington, NC 28403
(910) 798-7420, Fax (910) 798-7052
e-mail: fireforms@nhcgov.com



Serving and Protecting Wilmington since 1897

CITY OF WILMINGTON FIRE AND LIFE SAFETY

230 Government Center Dr Suite 150
Wilmington, NC 28403
(910) 343-0696, Fax (910) 341-0097
e-mail: fls@wilmingtonnc.gov

Is your project located in the unincorporated area of New Hanover County ___ or in the Wilmington City limits ___?

**COMMERCIAL UNDERGROUND STORAGE TANK REMOVAL
PERMIT APPLICATION & INSPECTION CHECKLIST**

CONTRACTOR REQUESTING PERMIT

NAME: _____ OFFICE PHONE _____
ADDRESS: _____ FAX _____
CONTACT PERSON: _____ CELL _____ E-MAIL _____
LICENSE # _____

TANK INFORMATION

LOCATION OF TANK(S) TO BE REMOVED _____
NAME OF BUSINESS/FACILITY _____
OWNER NAME: _____ PHONE _____
ADDRESS: _____ FAX _____
CONTACT PERSON: _____ CELL _____ E-MAIL _____

PERMIT INFORMATION

UST Tank Info	Tank #1	Tank #2	Tank #3	Tank #4	Tank #5
Tank Capacity					
Substance Stored					
Is Tank Regulated?					
Tank Constructed of					
Piping Constructed of					

The undersigned hereby makes application for a permit and the inspection of all work described above and hereby agrees to comply with all building regulations and other laws applicable to the use and type of work being performed.

Signature _____ Date _____

If applying for a City permit, you will be invoiced for any charges.

If applying for a County permit, please fill out the following.

Method of Payment: CASH CHECK CREDIT CARD CHARGE ACCOUNT # _____

FOR OFFICE USE BELOW THIS LINE

Approved by:	Date:	Fee:	Permit #
--------------	-------	------	----------

GENERAL TANK INFO	TANK #1	TANK #2	TANK #3	TANK #4	TANK #5
1. Tank capacity (gallons)					
2. Substance stored					
3. Is tank regulated?					
4. Construction material-tank					
5. Construction material-pipe					

TANK CLOSURE INFORMATION - Respond: Y=yes, N=no or ?-did not observe					
1. Product & piping removed from UST?					
2. Vapors purged or inserted from UST?					
3. UST filled with solid inert material (if abandoned)?					
4. Holes in tank observed?					
5. Free product observed in excavation?					
6. Groundwater in excavation?					
7. LEL of product within safe range?					
8. No smoking signs in placed within 25' of UST?					
9. All openings plugged except 1/4" vent for release of pressure?					
10. Tank labeled for former contents?					
11. Current vapor state labeled on tank?					
12. Warning against reuse labeled on tank?					
13. Vapor freeing method labeled on tank?					
All piping, gauge & tank fixtures, appurtenances, & vent disconnected & removed?					

INSPECTION COMMENTS
