



Finance
Purchasing Division
929 North Front St.,
10th Floor Post Office
Box 1810
Wilmington, NC
28402-1810

ADDENDUM NUMBER 1
HVAC LOOP REPLACEMENT AT THALIAN HALL
ITB # PB-IH-0225.1

WEDNESDAY, FEBRUARY 26, 2025

To all holders of bid documents: Please be advised of the following:

	Question/ Note (To be Advised of any Changes)	Response
1	I was wondering if you could confirm the size of the vertical mains inside the mechanical room?	We are unable to confirm the size of the vertical mains inside the mechanical room.
2	Curious about the idea of adding an additional set of isolation valves inside the mechanical room prior to wall the penetration leading to the six (6) fan coils on the 1st floor (this will allow for the isolation of the 1st floor, without having to isolate the whole system (upstairs).	The isolation valves coming from the vertical mains in the mechanical rooms are to be installed in the mechanical room. They can be installed closer to the vertical mains or closer to the mechanical room door for easier access, but the isolation valves will be in the mechanical room. All piping is to be replaced from vertical mains to each of the 6 units on the first floor per the scope of work.

All other terms and conditions remain unchanged.

Alissa Guarascio, Buyer
Purchasing Division

END OF ADDENDUM ONE