

**Finance**

Purchasing Division
929 North Front Street,
10th Floor
P O Box 1810
Wilmington, NC 28402-1810

910 341-7830
910 341-7842 fax
wilmingtonnc.gov
Dial 711 TTY/Voice

ADDENDUM NUMBER 4

***CITY OF WILMINGTON, NC
BRADLEY CREEK KAYAK LAUNCH
Contract: PS-DEI-0225
April 23, 2025***

To all holders of Bid Documents, please be advised of the following:

This addendum forms part of the proposal documents and modifies the original proposal document. Deletions, corrections, and changes shall be as binding as if incorporated in the original documents. All General Overviews, Terms and Conditions, basic requirements, and other specified details shall apply to these items.

1. General Provisions Section G-1.04.2 added by addendum #3 Bid Bond – **DELETED**
2. Clarification concerning boardwalk piles:
 - **Pile embedment of 18' shall be achieved of all boardwalk piles. If refusal is encountered before the target 18', the Contractor shall notify the Engineer who will make the final determination. To resist buoyant forces a minimum of 12' is required. Therefore, if the Contractor achieves refusal AND is beyond the minimum 12' embedment, they may proceed with other pile driving operations after notifying the Engineer.**

Acknowledge receipt of this Addendum in the space provided in the Bid. Failure to do so may disqualify the Bidder.

Christine R. Kareem, Sr. Contract Specialist
Purchasing Division
END OF ADDENDUM FOUR