



Finance
Purchasing Division
929 N Front St., 10th Floor
Post Office Box 1810
Wilmington, NC 28402-1810

910 341-7830
910 341-7842 fax
wilmingtonnc.gov
Dial 711 TTY/Voice

ADDENDUM NUMBER 1
Eastwood Road Median Improvements
EWR-KHA-0626
MAY 15, 2026

To all holders of Bid Documents, please be advised of the following:

Question: *Can we get the bid form in an excel format?*

Answer: Yes. It will be posted on the City's bid advertisement page for the project as an attachment. (SEE ATTACHED BID FORM)

Question: *Can the Pre-Bid sign-in-sheet be provided?*

Answer: Yes. It will be posted on the City's bid advertisement page for the project as an attachment.

Question: *Is the City going to perform density tests beneath new Curb & Gutter?*

Answer: Yes, density tests will be required in areas that are designed to be traffic bearing.

Question: *How will the gap between the face of the new curb and the face of the existing asphalt be paid for?*

Answer: This work will be paid for under the line items for Asphalt.

Question: *What defines "No Weekend Lane-Closures" as it relates to the NCDOT encroachment agreement?*

Answer: Nightly lane closures will be allowed Sunday through Thursday.

Acknowledge receipt of this Addendum in the space provided in the Proposal. Failure to do so may disqualify the Bidder.

All other terms and conditions remain unchanged.

Daryle L. Parker, Purchasing Manager
Purchasing Division
END OF ADDENDUM ONE