



Finance

Purchasing Division
929 N Front St., 10th Floor
Post Office Box 1810
Wilmington, NC 28402-1810

910 341-7830
910 341-7842 fax
wilmingtonnc.gov
Dial 711 TTY/Voice

ADDENDUM NUMBER 4

Pirate's Cove Drainage Improvements

DRA-MG-0826

August 12, 2026

To all holders of Bid Documents, please be advised of the following:

Question: The Mill and Overlay depth does not appear to be quantified anywhere, are you able to give a depth as the price is variable based on that depth.

Answer: City standard details 1-04 on sheet C-33 states for surface course replacement (i.e. the Mill and Overlay) Match ex. Asphalt or 2" min.

Acknowledge receipt of this Addendum in the space provided in the Proposal. Failure to do so may disqualify the Bidder.

All other terms and conditions remain unchanged.

Daryle L. Parker, Purchasing Manager
Purchasing Division

END OF ADDENDUM FOUR