



Finance

Purchasing Division
929 N Front St., 10th Floor
Post Office Box 1810
Wilmington, NC 28402-1810

910 341-7830
910 341-7842 fax
wilmingtonnc.gov
Dial 711 TTY/Voice

ADDENDUM NUMBER 1

Dawson-Wooster Streetscape Improvements

SW-WSP-0725

July 16, 2025

To all holders of Bid Documents, please be advised to the following Q & A:

1- Can the concrete scopes, signal scopes and grading scopes be performed in the daytime for this project on City Streets and NCDOT Dawson and Wooster Streets?

Work can be performed during daytime hours with the stipulation that the work does not occur within 5 feet of the travel lane or existing pedestrian facilities on Dawson Street and Wooster Street.

2- Can you provide the NCDOT Encroachment Agreement SP for ICT for NCDOT roads and work times, hours and traffic control for lane closure?

For NCDOT approved work times and hours, see SC28 in the approved Encroachment Agreement. Traffic control for lane closures will be installed per NCDOT standards as seen in section 1101 in the NCDOT Standard Drawings book.

3-Since the milling and Asphalt scopes are to be performed at night, is the contractor allowed to do a lane closure or traffic shift on Dawson and Wooster?

Yes, per the approved NCDOT Encroachment Agreement, lane closures are permitted at night between the hours of 8PM and 6AM. Weekend lane closures are not permitted.

4- Line Item 22 - 12" RCP Class IV. The pipe vendor no longer makes 12" RCP for NCDOT. Can this be changed to 15" RCP Class IV or 12" HPPP or 12" HDPE?

Design constraints limit pipe size in some specific locations to 12" RCP as shown in the plans. For the purpose of bidding, please submit a bid per what is shown in the plans. After the award, the City will consider alternate pipe material proposals, providing they comply with NCDOT requirements.

*5- Line Item 22 - 12" RCP Class V. The pipe vendor no longer makes 12" RCP for NCDOT. Can this be changed to 15" RCP Class V or 15" HPPP or 15" HDPE?
Can this be changed to 15" RCP Class IV or 12" HPPP or 12" HDPE?*

Design constraints limit pipe size in some specific locations to 12" RCP as shown in the plans. For the purpose of bidding, please submit a bid per what is shown in the plans. After the award, the City will consider alternate pipe material proposals, providing they comply with NCDOT requirements.

6- Can you provide a color for Flexible Porous Paving Sidewalk.

The color for all Flexible Porous Paving Sidewalk will be Granite by KBI Flexi-Pave. If the contractor wishes to use a different manufacturer, the contractor will need submit the desired product specification for review and approval by the City.

7- Looking through the specs for this project. I didn't see a spec for the S9.5B asphalt. I did see that they referred to section 610 of the NCDOT specifications. I know Wilmington has their own spec for asphalt and it is a lot different than DOT's. Just wanted to make sure they are going to use DOT approved Job mix formulas for the asphalt and not their special spec asphalt.

All asphalt to be used on this project will be DOT approved Job mix formulas.

Acknowledge receipt of this Addendum in the space provided in the Proposal. Failure to do so may disqualify the Bidder.

All other terms and conditions remain unchanged.

Daryle L. Parker, Purchasing Manager
Purchasing Division
END OF ADDENDUM ONE