



- NOTES:
1. CAP ALL CONDUCTORS WITH SILICONE SEALANT FILLED WIRE ENDS. LEAVE 24" MIN CONDUCTOR TAILS AT EACH BASE
 2. PRIMARY CONDUCTORS & CONDUIT TO BE SIZED BY ELECTRICIAN

STANDARD DETAIL		 <p>CITY OF WILMINGTON NORTH CAROLINA</p> <p>CITY OF WILMINGTON ENGINEERING PO BOX 1810 WILMINGTON, NC 28402 (910) 341-7807</p>
DATE:	SEPT, 2018	
DRAWN BY	JSR	
CHECKED BY	DLF, P.E.	
SCALE	NOT TO SCALE	
TYPICAL STREET BASE AND ELECTRIC DETAIL		<div style="border: 1px solid black; padding: 5px; display: inline-block;">SD 9-05</div>